

| | | | | | | | |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|-----------|------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------|---------------------------------------------------------------|------|
| DATE | 7/20/2020 & 08/11/2020 | | COUNTY | MARSHALL | ADDRESS | 1451 17TH RD | |
| CITY | HOME CITY | | LEGAL DESCRIPTION | S10 T03S R08E | | ACREAGE | 19.4 |
| OWNER'S NAME | LYNNE DEXTER & CHARLES L. SINKIE | | INSPECTED BY: | MARLENE STAMM | | | |
| DWELLING OCCUPIED? | YES | | IF NO, HOW LONG VACANT? | | | | |
| BEDROOMS # | THREE | BATHS# | THREE | DISHWASHER | ONE | GARBAGE DISPOSAL | |
| PURPOSE: | PRIVATE | COMPLAINT | REAL ESTATE | REFINANCE | OTHER | | |
| REAL ESTATE INFORMATION | CLOSING DATE | | 10/13/20 | | | | |
| REFINANCE/SELLER | BUYER | | PHONE | | 785-927-0204 | | |
| BUYER | ONLINE AUCTION | | PHONE | | | | |
| REALTOR | MARK SUDDUTH-SUDDETH REALTY | | PHONE | | 316-734-4175 | | |
| LENDER | | | PHONE | | | | |
| SEND REPORT TO | LYNNE DEXTER & CHARLES SINKIE | | PHONE | | | | |
| Section I. | | | | Section II. | | | |
| WATER SUPPLY | | | | WASTEWATER SYSTEM | | | |
| Pubic: | Municipal | RWD | Other | Public: | Municipal | Sewer District | |
| Private: | Drilled Well | Hand Dug | Other | Private: | Absorption Field | Lagoon | |
| Location: | WEST OF HOME | | | History (including age): | Holding Tank | OTHER | |
| Treatment: | None | Filter | Softener | Chlorinator | UNKNOWN | | |
| | Other: REVERSE OSMOSIS UNIT AT KITCHEN SINK | | | Location: | SOUTHEAST OF HOME | | |
| History of well: UNKNOWN | | | | Soil Conditions at time of inspection: | Dry | Wet | |
| | Y | N | Wastewater system more than 50' from surface water or well | Y | N | Wastewater system discharge onto ground surface | |
| | Y | N | System is a Cesspool | Y | N | Gray water (laundry, sinks, etc. in separate disposal system) | |
| | Y | N | Sufficient land area | Y | N | Adequate cleanouts between house and first treatment unit | |
| | Y | N | Septic Tank | Size: | gallons | | |
| | Y | N | Tank pumped for inspection? | Y | N | not required | |
| | Y | N | Tank last pumped: | Depth from ground surface to top of tank: _____ | | | |
| | Y | N | Concrete | + | Other | | |
| | Y | N | One Compartment | TWO COMP | Other | | |
| | Y | N | Lids and top of tank in good condition | Y | N | Inflow tee/baffle secure | |
| | Y | N | Water observed flowing back into tank from laterals | Y | N | Outflow tee/baffle securely in place | |
| | Y | N | Flow from house to tank obstructed | Y | N | Flow from house to tank obstructed | |
| | Y | N | Absorption Field | | | | |
| | Y | N | Chambers | Rock/Pipe | Bed System | Other | |
| | Y | N | Lagoon | | | | |
| | Y | N | Adequate Size | Y | N | Vegetation Controlled | |
| | Y | N | Adequate fence | Y | N | Hung gate in place | |
| | Y | N | Water Level: | High | Good | Low | |
| | Y | N | Water Color: | Green/Clear (Good) | Black/Gray (Bad) | Brown (Bad) | |
| | Y | N | Comments: | | | | |
| | Y | N | Contact Marlene Stamm, Sanitarian, with questions (785)770-2057. | | | | |
| <p>RED=DOES NOT MEET COUNTY SANITARY CODE REQUIREMENTS/NEEDS ATTENTION YELLOW=DOES MEET CODE REQUIREMENTS</p> | | | | <p>Meets current State (KDHE) and local standards? Y N</p> | | | |
| <p>Notes 1) LAGOON LACKS FENCE AND HAS MATURE TREE GROWTH INSIDE OF LAGOON AREA. TREES MUST BE REMOVED, FENCED AND REINSPECTED IN ORDER TO MEET SANITARY CODE REQUIREMENTS. ATTACHED IN INFORMATION ON FENCING REQUIREMENTS. CURRENT LOCATION MEETS SIZE AND SEPERATION DISTANCE REQUIREMENTS. 2) LAGOON APPEARS TO BE FUNCTIONING PROPERLY AT TIME OF INSPECTION. RECOMMEND TREATING DUCK WEED GROWTH ON TOP OF WATER TO INCREASE O2 LEVELS.</p> | | | | | | | |

Report is based on observations and/or water test results on date of inspection. This report does not guarantee longevity and future performance of well and/or wastewater system.